

## North Tower Building Specifications

Overall Size	Approx. 70,900 m <sup>2</sup> NLA (Office Floors)
No. of Office Floors	50 floors (8 <sup>th</sup> to 25 <sup>th</sup> , 27 <sup>th</sup> to 38 <sup>th</sup> , 39 <sup>th</sup> to 50 <sup>th</sup> )
Typical Floor Area	Approx. 1,700m <sup>2</sup> NLA
Finished Floor-to-Ceiling Height	2,750mm
Raised Floor	Approx. 180mm from top of slab to top of raised floor
Planning grid	1,200mm
Floor Loading	Office Floors: Live Load = 3.5 KN/m <sup>2</sup> ; Partitions = 1.0 KN/m <sup>2</sup>
Curtain Wall	Unitised aluminium system with double glazed low E-solar tinted or single thermal toughen glass
Total no. of carparks	713 lots for both towers (including handicap lots)
Toilets	Male and Female, 1 Executive with handicap and shower facilities
Pantry	Provision of common pantry on each floor
Air-conditioning	24-hour chilled water supply from District Cooling System with 2 AHUs per floor
	Estimated cooling load for a typical office floor is approx. 210kW per floor
	Space available for tenants' own air-conditioning equipment, subject to availability
	Auxiliary cooling water system with emergency power supply back-up
Security System	24-hour CCTV monitoring at all main entrances and exits Card Access Control, via turnstiles to lift lobbies
Fire Protection	Addressable fire alarm system. Automatic sprinkler network, smoke detector system; wet riser system, hose reels and portable fire extinguishers
Lighting	Average 500 lux at desktop level.

*The above information has been prepared with care. However, it is for guidance purposes only and is subject to change. It cannot form part of an offer or contract. While every reasonable care has been taken in providing this information, Raffles Quay Asset Management Pte Ltd, its subsidiaries, agents or representatives are not responsible for any errors or inaccuracies, or for the consequences of any reliance on such information, whether in the form of costs, claims, expenses, or other losses, and whether direct or indirect.*

Incoming Electrical Supply & Electrical Loads	2 separate 22 kV incoming power supply Lighting: 20 W/m <sup>2</sup> Power: 65 W/m <sup>2</sup>
Computer Earthing	Termination point provided at basement of the building, subject to available
Standby Generator	20% of estimated tenant normal load
Spare riser	For tenants' inter-floor cabling and specialized services, subject to availability
Space reserved for tenant's own generator	Space available for tenant's generator, subject to availability. Provision of fuel risers for connection to tenant's generator system
Telecommunication	Telephone, Fibre Optic (by service providers), MATV and SCV
Lifts	20 passenger lifts in 3 lifts zones with separate car park lifts (1 nos.) and service lifts (2 nos.)

*Updated as at 5 Feb 2020*

*The above information has been prepared with care. However, it is for guidance purposes only and is subject to change. It cannot form part of an offer or contract. While every reasonable care has been taken in providing this information, Raffles Quay Asset Management Pte Ltd, its subsidiaries, agents or representatives are not responsible for any errors or inaccuracies, or for the consequences of any reliance on such information, whether in the form of costs, claims, expenses, or other losses, and whether direct or indirect.*